

**ADDENDUM NO. 1
TO THE BID DOCUMENTS**

Project: Public Works Equipment Storage Building 2015
Addendum Issue Date: July 28, 2015
Bid Date: August 4, 2015 @ 2:00PM (Thursday)
Previous Addenda Issued: None
Issued By: Carey Meyer
Public Works Project Manager
City of Homer
Homer, AK 99603
cmeyer@ci.homer.ak.us

Bidders must acknowledge receipt of this addendum prior to the date set for bid opening by one of the following methods:

- (1) By acknowledging receipt of this addendum in the bid submitted.
- (2) By facsimile (fax) or email which will need to include a reference to the project and each of the addendum numbers.

The bid documents require acknowledgement individually of all addenda to the drawings and/or specifications. This is a mandatory requirement and any bid received without acknowledgment of receipt of addenda may be classified as not being a responsive bid.

The bid documents for the above project are amended as follows (all other terms and condition remain unchanged):

ITEM 1 – Clarification Regarding City Provided Foundation

Question: Will the city provide piling caps that the contractor can then weld his post brackets onto? Or will the city provide a finished foundation with post brackets in place on the pilings?

Answer: The City will provide a finished foundation with post brackets in place on the pilings.

ITEM 2 – Shed Siding

Question: On the plans it mentions both metal siding and T1-11 for exterior. We are planning on providing a bid to install T1-11. Is this acceptable?

Answer: The City wants only T1-11 siding. Ignore any references to metal siding.

Question: Do you want rough sewn T1-11 or pre-primed?

Answer: T1-11 siding shall be rough sewn.

(END Addendum #1)